Certificate of Compliance

Certificate: 1135455 **Master Contract:** 157406

Project: 80149251 **Date Issued:** 2023-04-10

Issued To: **Karl Dungs Inc**
3890 Pheasant Ridge Dr NE
Blaine, Minnesota, 55449
United States

Attention: Kevin Carlisle

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: Bob Greene
Bob Greene

PRODUCTS

CLASS - C333102 - REGULATORS (GAS) Gas Appliance Pressure
CLASS - C333182 - REGULATORS (GAS) Gas Appliance Pressure-Certified to U.S. Standards

Regulators

Trade Name: DUNGS

For Use With Natural, Manufactured, Mixed Gases, Propane, Liquefied Petroleum Gases and LP Gas-Air Mixtures

Model Number	Inlet Size	Outlet Size
FRI 7(05,07)/6	1/2	1/2
FRI 7(05,07)/6	3/4	3/4
FRI 7(05,07)/6	1	1

© 2018 CSA Group. All rights reserved.

FRI 7(10,12)/6	1	1
FRI 7(10,12)/6	1-1/4	1-1/4
FRI 7(10,12)/6	1-1/2	1-1/2
FRI 7(10,12)/6	2	2

APPLICABLE REQUIREMENTS

CSA/ANSI Z21.18:19•CSA 6.3:19 – Fourth Edition Gas Appliance Pressure Regulators

Notes:

Products certified under Class C333102, C333182 have been certified under CSA's ISO/IEC 17065 accreditation with the American National Standards Institute (ANSI). www.ansi.org

© 2018 CSA Group. All rights reserved.

Supplement to Certificate of Compliance

Certificate: 1135455 **Master Contract:** 157406

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80149251	2023-04-10	FIR follow-up, Update to Report 1135455 to address non-conformance noted in (FC# 157407) FIR dated October 27, 2022. Update Report 1135455 to the latest Standard edition CSA/ANSI Z21.18:19•CSA 6.3:19 per Certifications Inform, Gas Products No. 456.
70192314	2018-10-01	Updated Report #1135455 with new Vent Limiter drawings for models VL502-60 & VL502-61.
2678351	2014-03-20	Added new factory location (F5). Updated all applicable standards. Updated the Manufacturing & Production Test Plan. Added the VL 502/60 and VL 502/61 vent limiters.
1633680	2005-01-21	Update to ANSI Z21.18a-2001.

© 2018 CSA Group. All rights reserved.